

## **RFP No. 2022-02, 19<sup>th</sup> Hole Kitchen and Walk-in Coolers Q&A**

1. What is the estimated cost of the Walk-in Cooler Project?

The estimated cost is \$184,562.

2. What are the sizes of the walk-in coolers?

The Lounge (by the main pool) 10' wide x 27' long. Refrigeration part 10' x 20' the freezer section 10' x 7'. This new cooler replaces the older one in a new space to the right and will require a new slab.

The 19<sup>th</sup> Hole (by the Golf course) 10' 8" wide x 20' long. Refrigeration section 10' 8" x 12'. Freezer section 10' 8" x 8'.